



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
TURKISH STANDARDS INSTITUTION

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

**1783-CPR-856**

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Cable Type : NA2XH (MULTICORE)**

**Reaction to Fire Performance: Cca, s1b, d2, a1**

**(SCOPE IS AT THE ATTACHMENT)**

placed on the market under the name or trade mark of

**SAHRA KABLO SANAYİ TİCARET ANONİM ŞİRKETİ**  
**SARAY MAHALLESİ AHMET TEVFİK İLERİ CADDESİ NO:16 ÜMRANIYE**

and produced in the manufacturing plant

**SAHRA KABLO SANAYİ TİCARET ANONİM ŞİRKETİ**  
**SARAY MAHALLESİ AHMET TEVFİK İLERİ CADDESİ NO:16 ÜMRANIYE**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 50575: 2014 + A1: 2016**

under system 1 + for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product .**

This certificate was first issued on 06.07.2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, Rev. 0, 06.07.2018



Sezai DOĞAN  
Director of Directives



# TÜRK STANDARDLARI ENSTİTÜSÜ

TURKISH STANDARDS INSTITUTION

## ATTACHMENT OF THE CERTIFICATE OF CONSTANCY OF PERFORMANCE

### PRODUCT DESCRIPTION:

Designation of cable family	NA2XH
Rated voltage	0,6 / 1 kV

### RELEVANT CONSTRUCTIONAL INFORMATION:

Conductor design	Round
Conductor class	2
Number of cores	Multi core
Concentric shield	Does not include
Armour	Does not include

### ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE TS CLC TS 50576:

Covered field
<input type="checkbox"/> Armoured
<input checked="" type="checkbox"/> Unarmoured multicore
<input type="checkbox"/> Single core sheated
<input type="checkbox"/> Single core unsheated
<input type="checkbox"/> Cable family including diameter $\leq$ 5mm

### CROSSECTIONS IN THE SCOPE:

Number of cores	Cross-sections mm <sup>2</sup>
2	10-16-25-35-50-70-95-120-150-185-240-300
3	16-25-35-50-70-95-120-150-185-240-300
3+1	16+10-25+16-35+16-50+25-70+35-95+50-120+70-150+70-185+95-240+120-300+150
4	16-25-35-50-70-95-120-150-185-240-300
5	10-16-25-35-50-70-95-120-150-185-240



Attachment of the Certificate of Constancy of Performance, 1783-CPR-856.